

ELECTRIFICATION OF MILWAUKEE BRANCH
OF THE
CHICAGO AND NORTHWESTERN RAILWAY

BY

H. L. CASE
F. FERNANDEZ - MAREQUE
A. F. SCHOEMBS
R. W. WHITMORE

ARMOUR INSTITUTE OF TECHNOLOGY

1914

621.33
C 26



Illinois Institute
of Technology
UNIVERSITY LIBRARIES

AT 325

Case, H. L.

Proposed electrification of
the Milwaukee branch,

For Use In Library Only

PROPOSED ELECTRIFICATION
of
THE MILWAUKEE BRANCH
CHICAGO & NORTHWESTERN RAILWAY

A THESIS

PRESENTED BY

H. L. Case
F. Fernandez-Mareque
A. F. Schoombs
R. W. Whitmore

TO THE

PRESIDENT AND FACULTY

OF

ARMOUR INSTITUTE OF TECHNOLOGY

FOR THE DEGREE OF

BACHELOR OF SCIENCE IN ELECTRICAL ENGINEERING

HAVING COMPLETED THE PRESCRIBED COURSE OF STUDY IN

ELECTRICAL ENGINEERING

May 1914

Approved
E. H. Freeman
Professor of Electrical Engineering
H. M. Raymond
L. C. Morin

CONTENTS.

Introduction - - - - -	page, 1
The Speed-time Curve - - - - -	2
Choice of acceleration - - - - -	2
Car weight - - - - -	8
Choice of motors and gear ratio -	8
Schedule - - - - -	17
Cars and Equipment - - - - -	19
Distribution System - - - - -	20
Spot map - - - - -	20
Trolley section - - - - -	20
Number of substations - - - - -	21
Location of substations - - - - -	22
Feeders. - - - - -	22
Substations - - - - -	23
General description - - - - -	23
Operation - - - - -	24
Specifications - - - - -	25
Transmission Line - - - - -	28
Choice of wire - - - - -	28
Capacity and inductance - - - - -	31
Natural period of the line - - - -	32

Transmission Line (Cont'd)

Power house voltage - - - - -	page, 33
Regulation - - - - -	34
Charging current, etc - - - - -	33
Power House - - - - -	35
Location - - - - -	35
Power curve - - - - -	35
Equipment - - - - -	36
Switchboard - - - - -	39



INTRODUCTION.

This thesis covers in a brief way, the design of a complete railway installation for the proposed "Electrification of the Chicago-Milwaukee Branch of the Chicago and Northwestern Railway".

We have attempted to indicate a general method of procedure, including sample calculations and conclusions drawn therefrom; estimate the cost of the installation and maintenance; and compute the net earnings of the proposed system.

In the preparation of this thesis many valuable suggestions have been made by Professors Freeman, Snow, and Nichols, of the Armour Institute of Technology.

No attempt has been made to enter into the details of all or any particular portion of the design. Such a task as a detail design could only be accomplished by a Board of Engineers with at least two or three years time to devote to the subject.

MEMORANDUM

TO : THE PRESIDENT

FROM : THE SECRETARY OF DEFENSE

SUBJECT: [Illegible]

1. [Illegible]

[Illegible]

2. [Illegible]

3. [Illegible]

4. [Illegible]

5. [Illegible]

6. [Illegible]

[Illegible]

7. [Illegible]

8. [Illegible]

9. [Illegible]

[Illegible]

10. [Illegible]

11. [Illegible]

12. [Illegible]

13. [Illegible]

14. [Illegible]

[Illegible]

THE SPEED TIME CURVE.

In the preliminary calculation and determination of the speed-time curve the following factors have been considered:

- (a) Choice of acceleration, involving distance between stops, the average speed, and weight of car.
- (b) The profile of the line.
- (c) Choice of motor and gear ratio.
- (d) Frequency of the service.

Choice of Acceleration.

The general solution of the problem is here considered because of its important relation to the choice of motors, a factor which directly determines the initial cost of the entire system.

Referring to Fig. 1, an arbitrarily assumed straight line speed-time curve for a straight and level track, the following notation has been used:

a - Acceleration in miles per hour per second along OA ($=DA+OD$)





- b - Retardation during braking ($=Ab+ED$)
- c - Retardation during coasting ($=BE+EC$)
- x - Time required to go from O to A. ($=OD$)
- y - Time for AB ($=DE$)
- z - Time for BC ($=EC$)
- s_1 - Distance for OA. ($=\text{Area OAD}$)
- s_2 - Distance for AB. ($=\text{Area DABE}$)
- s_c - Distance for BC. ($=\text{Area EBC}$)
- T - Total time of run. ($=OC$)
- L - Total distance. ($=\text{Area OABC}$)
- V - Average velocity. ($=0.682 L+T$) (one
mile per hour = 0.682 feet per second)

As indicated in the figure the car is assumed to be moving with a constant acceleration up to its maximum speed for a time OD, then is retarded at a constant coasting rate for a time DE, and finally is retarded during braking at a constant acceleration over a period of time equal to EC.

The velocities, times, and distances referred to in the foregoing discussion may be represented by the three following equations:

$$(1) ax - by - cz = 0$$

$$(2) x + y + z = T$$

$$(3) ax^2 - by^2 + cz^2 + 2axy = 2 \times 0.682 L.$$

$$\text{Put: } \frac{x}{T} = \xi ; \frac{y}{T} = \eta ; \frac{z}{T} = \zeta$$

$$\text{Then: } \xi + \eta + \zeta = 1$$

$$a\xi^2 - c\eta - b\zeta = 0$$

$$a\xi^2 - a\xi\eta + b\eta\xi + b\zeta^2 = 2 \frac{L}{T^2} = 2A$$

$$\text{Where } A = 0.682 L + T^2.$$

$$\eta = \frac{b - (b+a)\xi}{b-c}$$

$$\zeta = \frac{(a+c)\xi - c}{b-c}$$


" ξ ", is now found in terms of "a" and "A".

This is accomplished by assuming average values for coasting and braking as 0.15 and 2.0, respectively, substituting same in the preceding equations, and solving for ξ for different values of "A" and "a". The results of such a calculation are shown by the curves of Fig. 2.

By use of the general equations of the speed-time curve, table 1 was calculated, a sample of the procedure being given below:

$A = 0.682 L + T^2$, where L is the average length of run, a factor which was determined

Fig 2





T A B L E 1.

a	A	T	S	x	w-70	KW./ton	
1.0	.15	175.9	24.30	38.7	48.9	4.08	.220
	.20	152.3	27.70	43.3	61.2	4.57	.284
	.25	136.1	30.70	49.4	79.8	5.21	.363
	.30	124.3	33.30	59.3	114.8	6.26	.477
	.35	115.1	35.65	----	-----	-----	-----
	.40	107.6	37.90	----	-----	-----	-----
	.45	101.5	39.80	----	-----	-----	-----
	:	:	:	:	:	:	:
	:	:	:	:	:	:	:
	:	:	:	:	:	:	:
1.5	.15	175.9	24.30	26.7	50.2	6.06	.152
	.20	152.3	27.70	28.9	58.7	6.56	.190
	.25	136.1	30.70	31.9	71.3	7.25	.234
	.30	124.3	33.30	35.0	86.1	7.95	.282
	.35	115.1	35.65	39.4	108.7	8.95	.342
	.40	107.6	37.90	47.0	155.0	10.67	.437
	.45	101.5	39.80	----	-----	-----	-----
	:	:	:	:	:	:	:
	:	:	:	:	:	:	:
	:	:	:	:	:	:	:
2.0	.15	175.9	24.30	19.87	47.9	7.80	.113
	.20	152.3	27.70	21.00	53.5	8.25	.138
	.25	136.1	30.70	23.15	65.1	9.10	.170
	.30	124.3	33.30	25.30	77.4	9.94	.203
	.35	115.1	35.65	27.18	89.6	10.68	.236
	.40	107.6	37.90	31.10	117.5	12.24	.289
	.45	101.5	39.80	36.20	159.3	14.22	.357

following an investigation of the number of stops and the distance between same. The particular run under consideration was chosen as that between Chicago and Waukegan, because the maximum traffic occurs between these two points.

$$\text{Then } 0.682 L = 4640$$

Then from curve of Fig. 2, for $A=.15$ and $a=1$

$$T = \sqrt{\frac{4640}{.15}} = 175.9$$

$S =$ miles per hour $= \frac{0.682 L}{T + \tau}$, where τ is the stopping time (≈ 15 seconds).

$$\text{Therefore } S = \frac{4640}{175.9 + 15} = 24.3$$

$$X = \int T = .220 \times 175.9 = 38.7$$

(\int obtained from curve.)

$W_{70} =$ Watts per tone mile at 70% efficiency.

$$W_{70} = \frac{\{91.1a^2 + fa\}^{\frac{1}{2}}}{0.7 A} = 48.9$$

$f =$ Lbs. friction per ton $= 15$.

$$\text{KW/ton} = \frac{\{91.1a + \frac{fx}{2}\} \cdot 1.47 \cdot 0.746}{550} = 4.08$$

After a careful study of Table 1, an acceleration of 1.5 with a running time of 136.1 seconds was chosen as being the most economical acceleration and time of run.

Choice of Motors and Gear Ratio.

From practical operating conditions of roads similar to the one under consideration the car weight including 62 passengers was set at 45 tons. The motor capacity was estimated at about 460 H.P., equally divided among four motors.

Of the various motors considered the 303A Westinghouse Railway Motor was found best adapted to the conditions. This conclusion was arrived at as follows: the performance curves of the given motor were plotted for different values of gear ratio, as shown in Figs. 3, 4, and 5; the data being obtained from the manufacturer. From the appearance of a few preliminary speed-time curves, the time of run was set at 140 seconds. A sample calculation and outline of the method employed in plotting the speed-time curve is given below:

Straight and level track assumed.

Given:

Gear ratio=2.21; $a=1.5$; $f=15$; car weight

of 45 tons; 4 - 115 H.P. motors.

Therefore, tons per motor = $45 \div 4 = 11.25$

Since $91.1a = p - f$, where p = Lbs. tractive effort per ton,

Then $91.1 \times 1.5 = p - 15$.

Or, $p = 151.7$ Lbs. per ton.

From the motor curve for a tractive effort of $1710 = 151.7 \times 11.25$, I is found to be 182 amperes. Then when $I = 182$ amperes, $V = 27.5$ (from Fig. 4).

It is evident that by varying the current supplied to the motor, the tractive effort can be kept constant up to a speed of 27.5 miles per hour, at which time the motor will operate according to its characteristic. The accelerating portion of the curve was then drawn; it being a straight line up to 27.5. A sample calculation for the motor curve is given below and the data used in plotting the curve is given in Fig. 2.

$$dt = \frac{91.1 dv}{p - f} = \frac{91.1 \times 2.5}{106.7 - 15} = 2.48$$

dv , assumed at 2.5, then $V = 27.5 + 2.5 = 30$.

When $V = 30$, $p = \frac{P}{11.25} = \frac{1200}{11.25} = 106.7$; (P taken from

tractive effort curve).

Fig. 3
Performance Curves
of
Westinghouse
507A Railway Motor
Ratio 3:81






Fig 4
Performance Curves
of
Westinghouse
303 A Railway Motor
Ratio 2.21







Fig 5
Performance Curves
Of
Westinghouse
303 A Railway Motor
Ratio 2.95









Fig. 6
PRELIMINARY
SPEED TIME CURVES



T A B L E 2.

dv	:	V	:	dt	:	t
.	:	27.5	:	----	:	18.3
2.5	:	30.0	:	2.48	:	20.78
3.0	:	33.0	:	4.20	:	24.98
3.0	:	36.0	:	5.80	:	30.78
3.0	:	39.0	:	7.14	:	37.92
3.0	:	42.0	:	9.85	:	47.77
3.0	:	45.0	:	12.20	:	59.97
3.0	:	48.0	:	18.00	:	77.97
3.0	:	51.0	:	37.90	:	115.87
3.0	:	54.0	:	97.50	:	213.37

TABLE I

1	2	3	4
1.00		1.00	1.00
1.01	1.01	1.01	1.01
1.02	1.02	1.02	1.02
1.03	1.03	1.03	1.03
1.04	1.04	1.04	1.04
1.05	1.05	1.05	1.05
1.06	1.06	1.06	1.06
1.07	1.07	1.07	1.07
1.08	1.08	1.08	1.08
1.09	1.09	1.09	1.09
1.10	1.10	1.10	1.10
1.11	1.11	1.11	1.11
1.12	1.12	1.12	1.12
1.13	1.13	1.13	1.13
1.14	1.14	1.14	1.14
1.15	1.15	1.15	1.15
1.16	1.16	1.16	1.16
1.17	1.17	1.17	1.17
1.18	1.18	1.18	1.18
1.19	1.19	1.19	1.19
1.20	1.20	1.20	1.20
1.21	1.21	1.21	1.21
1.22	1.22	1.22	1.22
1.23	1.23	1.23	1.23
1.24	1.24	1.24	1.24
1.25	1.25	1.25	1.25
1.26	1.26	1.26	1.26
1.27	1.27	1.27	1.27
1.28	1.28	1.28	1.28
1.29	1.29	1.29	1.29
1.30	1.30	1.30	1.30
1.31	1.31	1.31	1.31
1.32	1.32	1.32	1.32
1.33	1.33	1.33	1.33
1.34	1.34	1.34	1.34
1.35	1.35	1.35	1.35
1.36	1.36	1.36	1.36
1.37	1.37	1.37	1.37
1.38	1.38	1.38	1.38
1.39	1.39	1.39	1.39
1.40	1.40	1.40	1.40
1.41	1.41	1.41	1.41
1.42	1.42	1.42	1.42
1.43	1.43	1.43	1.43
1.44	1.44	1.44	1.44
1.45	1.45	1.45	1.45
1.46	1.46	1.46	1.46
1.47	1.47	1.47	1.47
1.48	1.48	1.48	1.48
1.49	1.49	1.49	1.49
1.50	1.50	1.50	1.50
1.51	1.51	1.51	1.51
1.52	1.52	1.52	1.52
1.53	1.53	1.53	1.53
1.54	1.54	1.54	1.54
1.55	1.55	1.55	1.55
1.56	1.56	1.56	1.56
1.57	1.57	1.57	1.57
1.58	1.58	1.58	1.58
1.59	1.59	1.59	1.59
1.60	1.60	1.60	1.60
1.61	1.61	1.61	1.61
1.62	1.62	1.62	1.62
1.63	1.63	1.63	1.63
1.64	1.64	1.64	1.64
1.65	1.65	1.65	1.65
1.66	1.66	1.66	1.66
1.67	1.67	1.67	1.67
1.68	1.68	1.68	1.68
1.69	1.69	1.69	1.69
1.70	1.70	1.70	1.70
1.71	1.71	1.71	1.71
1.72	1.72	1.72	1.72
1.73	1.73	1.73	1.73
1.74	1.74	1.74	1.74
1.75	1.75	1.75	1.75
1.76	1.76	1.76	1.76
1.77	1.77	1.77	1.77
1.78	1.78	1.78	1.78
1.79	1.79	1.79	1.79
1.80	1.80	1.80	1.80
1.81	1.81	1.81	1.81
1.82	1.82	1.82	1.82
1.83	1.83	1.83	1.83
1.84	1.84	1.84	1.84
1.85	1.85	1.85	1.85
1.86	1.86	1.86	1.86
1.87	1.87	1.87	1.87
1.88	1.88	1.88	1.88
1.89	1.89	1.89	1.89
1.90	1.90	1.90	1.90
1.91	1.91	1.91	1.91
1.92	1.92	1.92	1.92
1.93	1.93	1.93	1.93
1.94	1.94	1.94	1.94
1.95	1.95	1.95	1.95
1.96	1.96	1.96	1.96
1.97	1.97	1.97	1.97
1.98	1.98	1.98	1.98
1.99	1.99	1.99	1.99
2.00	2.00	2.00	2.00

The braking line was then drawn with a slope of 2.0, in such a position as to meet the time axis at 140. The coasting line of slope 0.15 was placed in such a manner that the area of the curve was equal to the length of the run.

Curves for the other two gear ratios were plotted in a similar manner and it was found that the motor with a ratio of 3.81 could not make the run in the required time. The problem was then reduced to a selection of one of the two remaining ratios.

The final choice was made by plotting current curves for each gear ratio, and as can be seen from Fig. 6, the motor with a gear ratio of 2.85 consumed the smaller amount of power. The mean effective value of current was calculated and as this came within the continuous rating of the motor and at the same time was not too low, a factor which would condemn the motor as being too large, the motor of 2.85 ratio was chosen.

The type of motor having been decided upon

the final speed-time curves were plotted and are shown on Plates 1 and 2. The calculations for these curves are the same as those mentioned heretofore, with the exception that retarding forces due to grades and curves were considered, same being obtained from the profile of the line. The retarding or accelerating force "G" due to grades, depending on whether the grade is positive or negative, was taken as 200 times the per cent grade; and the retarding force per ton due to curves was set as $0.5 \times$ the degree of curvature. A general equation is:

$$91.1a = p - f - G - C.$$

In case the car is to be started on an up-grade the value of "a" must be calculated because the acceleration for a level track was set at 1.5 and the rheostat was designed accordingly, therefore the starting torque per ton is not to be greater than 151.7, as computed for a straight and level track. The value of "a" for any condition is readily determined by substituting the values of p , f , G , and C in the above equation.

THE
JOURNAL
OF THE
ROYAL ANTHROPOLOGICAL INSTITUTE

Volume 10, Part 1, 1880
CONTENTS
The Origin of the Human Race, by H. H. S. G. ...
The Human Brain, by J. ...
The Human Voice, by ...
The Human Eye, by ...
The Human Ear, by ...
The Human Nose, by ...
The Human Mouth, by ...
The Human Throat, by ...
The Human Lungs, by ...
The Human Liver, by ...
The Human Stomach, by ...
The Human Intestines, by ...
The Human Urinary Organs, by ...
The Human Reproductive Organs, by ...
The Human Skin, by ...
The Human Hair, by ...
The Human Nails, by ...
The Human Bones, by ...
The Human Muscles, by ...
The Human Blood, by ...
The Human Lymph, by ...
The Human Saliva, by ...
The Human Sweat, by ...
The Human Tears, by ...
The Human Urine, by ...
The Human Feces, by ...
The Human Semen, by ...
The Human Ova, by ...
The Human Embryo, by ...
The Human Fetus, by ...
The Human Infant, by ...
The Human Child, by ...
The Human Adolescent, by ...
The Human Adult, by ...
The Human Old Age, by ...

THE
JOURNAL
OF THE
ROYAL ANTHROPOLOGICAL INSTITUTE
Volume 10, Part 2, 1880
CONTENTS
The Human Race, by H. H. S. G. ...
The Human Brain, by J. ...
The Human Voice, by ...
The Human Eye, by ...
The Human Ear, by ...
The Human Nose, by ...
The Human Mouth, by ...
The Human Throat, by ...
The Human Lungs, by ...
The Human Liver, by ...
The Human Stomach, by ...
The Human Intestines, by ...
The Human Urinary Organs, by ...
The Human Reproductive Organs, by ...
The Human Skin, by ...
The Human Hair, by ...
The Human Nails, by ...
The Human Bones, by ...
The Human Muscles, by ...
The Human Blood, by ...
The Human Lymph, by ...
The Human Saliva, by ...
The Human Sweat, by ...
The Human Tears, by ...
The Human Urine, by ...
The Human Feces, by ...
The Human Semen, by ...
The Human Ova, by ...
The Human Embryo, by ...
The Human Fetus, by ...
The Human Infant, by ...
The Human Child, by ...
The Human Adolescent, by ...
The Human Adult, by ...
The Human Old Age, by ...

The curves as plotted are for a 600 volt 303A motor, therefore since the series-parallel operation is to be used with a trolley voltage of 1200, the current per car is given by the current curve for such times as all motors are in series. At other points the current per car is twice that shown by the curve.



SCHEDULE.

The traffic over the line having been well established for operation as a steam road the matter of drawing up a schedule for the proposed system was a more or less simple matter. Conditions of traffic operation were considered with the General Passenger Agent of the road and our conclusion as to the best schedule to be followed is indicated on plates 3 and 4. The trains to be operated in accordance with this schedule consist of seven cars for all trains from Chicago to Milwaukee or vice versa; five cars for the Chicago-Waukegan and intermediate, and of two cars for the Kenosha-Milwaukee service.

Without doubt it is true that it would, if possible, be better to have a more frequent schedule of fewer cars per train thus making a saving in the first cost of the feeder system, but upon investigation it was found that the traffic at the present time and for some time to come was of such a nature that trains made

up of several cars would be required for all
through trains to Milwaukee.

CARS AND EQUIPMENT.

The cars suggested, are those of The McGuire-Cummings Manufacturing Company's standard type passenger coach with a seating capacity of 62 persons, equipped with four 600 volt 303A, Westinghouse Railway Motors. The motors gear drive to 33-inch wheels with a ratio of 2.85 . The starting equipment is to be that of the Westinghouse multiple-unit control system. The general specifications for car and equipment are the same as those adopted by the American Car Builders Association. The estimated cost of car complete with equipment, was set at \$9000.

THE HISTORY OF THE

REIGN OF KING CHARLES THE FIRST

IN WHICH ARE CONTAINED THE
MOST IMPORTANT AND INTERESTING
CIRCUMSTANCES OF HIS REIGN
FROM HIS MARRIAGE TO HIS DEATH
IN THE YEAR 1649. BY
JOHN BURNET, BISHOP OF SALISBURY.
IN TWO VOLUMES. THE SECOND
VOLUME. LONDON, Printed by
J. Streater, at the Sign of the Gun,
in St. Dunstons Church, in Fleet-
street, 1724.

DISTRIBUTION SYSTEM.

Spot Map.

On inspection of the schedule, speed-time and power curves it was found that the maximum load occurred between 7:40 A.M. and 8:30 A.M. A spot map as shown on Plate 5 was then plotted, the total length divided into 28 sections and the average number of cars per section noted. The current per section was calculated on the assumption that each car consumed 100 amperes as an average value. It will be noted that the sum of all the average number of cars when multiplied by 100 amperes is equal to the maximum current indicated by the power curve; therefore it is evident that the spot map represents an average maximum condition.

Substations.

The number of substations for the system was determined by means of the following equation:*

$$\lambda^2 = \frac{n^2 W^2 L + k_2 g^2 m L}{1.77 L I_0 V p m k_2 C_2 C_3 + \frac{P^2}{g^2} (C_2 g_2 h)} \text{ feet}$$

*(From "Electric Traction and Transmission Engineering", Sheldon & Hausman - P.186.)

n' - attendants per station - - - - - 3
 w' - attendants salary per year - - - \$800.
 L - length of road in feet - - - - 446,910
 p_3 - annual rate covering interest - \$0.15
 f'_3 - cost constant - - - - - 4600
 u - number of units - - - - - 3
 I_0 - mean effective amperes per foot .015
 - conductor resistance in ohms - - - 10
 w - weight per mil-foot in lbs.- .00000303
 p_2 - annual charge against the
 contact conductor - - - - - \$0.06
 c_2 - cost of conductor per lb. - - - \$0.18
 c_3 - cost of power per kilowatt hour
 delivered from substation - - - \$0.01
 P - maximum capacity
 - rated installed capacity $\underline{P^2} = 20,000$
 c'_3 - cost /kW Hr delivered to substation
 \$0.01
 g_3 - constant for conversion.
 h - equivalent annual hours of operation.

The solution of the equation resulted in the choice of seven substations.

Location of Substations.

The trolley sections previously decided upon were divided into seven parts and the proper location of the substations determined by finding the center of gravity of each division. The current per trolley section was considered as a mechanical load. As a result of this scheme the most economical location of the stations, in thousand feet from Chicago, were found to be: 24.5; 70.6; 115.0; 178.0; 262.0; 350.0; and 418.0

The location of the substations having been decided upon the size of the feeders was calculated on a basis of a 200 volt drop between station bus and end of any feeder. The sizes of positive feeders for one substation are shown on Plate 6.

SUBSTATIONS.

General Description.

The seven substations previously decided upon are suggested as being of the rotary converter type of 2000 K.W. rated capacity. Each station is to be equipped with three six-phase 1000 K.W. General Electric synchronous converters connected to switch gear apparatus in such a manner that any two of the machines can be operated in series on the direct current side. The alternating current end of each rotary is to be connected to a bank of three single phase oil cooled Allis-Chalmers transformers, delta connected on both high and low tension sides. The oil switches connecting the transformers with the high tension bus are to be of the General Electric H₆ type. The one extra converter has been supplied in insure continuous service. The lightning arresters and choke coils have been so chosen and arranged as to give ample protection from storm disturbances.

Operation.

In connection with the starting apparatus of the synchronous converter a field breakup and reversing switch is to be mounted on the frame of each machine. At the moment the machine is connected to the alternating current side, the field switch must be open. The converter being started as an ordinary induction motor by varying the impressed voltage by means of a three pole double throw switch connected to low voltage taps of the transformers as indicated in the wiring diagram.

Full voltage is not to be applied to the machine until the polarity has been determined. As soon as the rotary has nearly reached synchronism, the voltmeter which is located on the switchboard and connected across the direct current terminals of the machine, will indicate the polarity of the apparatus. In case the polarity happens to be the one desired the field switch is closed and the full alternating voltage applied. In case the direct voltage builds up

reversed the field switch is thrown to the reversed position. This operation causes the field flux to oppose the armature flux with the result that the armature flux is in effect pushed aside and the converter "slips a pole". The polarity at the same time is reversed.

Either of the two remaining rotaries is then started in a similar manner and finally put in series by means of switches which are so interlocked that the operator cannot connect any two machines in parallel on the direct current side.

The speed limit device must be tested so as to obtain proper operation before the machine on which it is to be installed is put into service.

The apparatus is protected on both sides of the machine with overload relays.

Specifications.

The specifications of all apparatus will be standard, only the performance being consid-

THE UNIVERSITY OF CHICAGO
LIBRARY
1215 EAST 58TH STREET
CHICAGO, ILL. 60637
U.S.A.
TEL: 773-936-5000
FAX: 773-936-5001
WWW.CHICAGO.EDU
CHICAGO, ILL. 60637
U.S.A.
TEL: 773-936-5000
FAX: 773-936-5001
WWW.CHICAGO.EDU

ered in this discussion.

Rotary Converter.

After a run of 24 hours at full load the temperature rise of the armature and field coils shall not be more than 35° C. The machine when operated at 150% overload shall not indicate a temperature rise of more than 55° C. after a two hour run.

Relative to overload capacity, the machine must be of such design as will carry a 50% overload without movement of the brushes and without injurious sparking, and an overload of 100% at full voltage momentarily without flashing over or injurious sparking.

The efficiency of the machine to be as follows:

150%	Full load	- - - -	97.0%
100%	" "	- - - -	96.5%
75%	" "	- - - -	96.0%
50%	" "	- - - -	94.5%

Transformers.

After a run of 24 hours at full load, the rise of temperature of any part of the transformer shall not exceed 35° C. The transformer must be of such design as will carry an overload of 25% without greater rise of temperature than 57° C.

The efficiency is to be as follows:

150%	Full load	- - - -	98.3%
100%	" "	- - - -	98.3%
75%	" "	- - - -	98.2%
50%	" "	- - - -	97.8%
25%	" "	- - - -	96.2%

TRANSMISSION LINE.

Choice of Wire.

The distance between the power house and substation No. 5 is 63,000 feet. The load up to this station is 6250 K.W.

Assume the following:

Phases - - - - - 3

Receiver voltage 30000

Cycles - - - - - 25

Loss - - - - - 2%

Loss = 125 K.W.

Loss per wire = 46.1 K.W.

$I = 120$ amperes.

$R = 41600 \div 120^2 = 2.9$ ohms.

R per 1000 feet = $2.9 \div 63 = 0.046$

Wire required: #0000 copper or 400,000

cir. mils aluminum.

Consider a #0000 copper wire.

Resistance per 1000 feet = 0.048

Line resistance = $0.048 \times 63 = 3.2$

Power loss = $120^2 \times 3.2 = 46,000$ watts.

Cost of 46 K.W. per year = \$4030.

Cost of 1000 feet #0000 wire = \$400.

Cost of 63,000 feet = \$25,200.

Interest and depreciation = \$1512.

Annual charge against copper = \$26,712.

Consider a #000 copper wire.

Resistance per 1000 feet = 0.06 ohms.

Line resistance = 3.78

Power loss = 54.4 K.W.

Cost of 54.4 K.W. per year = \$4660.

Annual charge against copper = \$23,956.

Saving on copper = \$26,712. - \$23,956 = \$2756.

Increase in cost of power = \$630.

Net saving = \$2756. - \$630. = \$2126.

Consider a #1 copper wire.

Resistance per 1000 feet = 0.1215

Line resistance = 7.65

Cost of power lost = \$9600.

Annual charge against copper = \$13,356.

A #2 copper wire indicates a small saving over the #1, but inasmuch as the current would not be well within the current carrying capacity

the #1 wire was selected as being the most economical size of wire as far as first cost and copper wire itself were concerned.

Consider a #000 aluminum wire.

Resistance per 1000 feet = 0.0996

Line resistance = 6.2

Power loss = 90.400 watts.

Cost of 90.4 K.W. per year = \$7920.

Cost of wire = \$13,800.

Annual charge against aluminum = \$14,628.

Consider a #00 aluminum wire.

Resistance per 1000 feet = 0.125

Line resistance 7.87

Power loss = 113,000

Cost of 113 K.W. per year = \$9900.

Cost of wire = \$11,500.

Annual charge = \$12,190.

Saving on aluminum = \$2438.

Increase in cost of power = \$1980.

Net saving of \$350.

The wires now considered are the #000 aluminum and the #1 copper. The relative costs are given below:

Wire	:	Cost of wire	:	Cost of power.	:	Total
#000 Al.	:	\$14,628.	:	\$7920.	:	\$22,548.
#1 Cu.	:	\$13,356.	:	\$9600.	:	\$22,956.

The #000 aluminum wire was selected because of its first cost; weight, a factor which determines the size of the towers or poles; and because of its greater tensile strength.

Spacing of Wires.

The wires are to be arranged in delta, 36 inches apart. (?)

Capacity and Inductance per Wire.

The inductance per wire equals L.

$$L = 2 \left(\log_e \frac{2 + \frac{1}{4}}{r} - \log_e \frac{2}{D} \right)$$

$$L \text{ per foot} = L_1.$$

$$L_1 = 2 \times 12 \times 2.54 \left(\log_e \frac{2 \times 12}{.41} + \frac{1}{4} - \log_e \frac{24}{36} \right) 10^{-9}$$

$$= 264 \times 10^{-9} \text{ henrys.}$$

$$\text{Length of line} = 63,000 \text{ feet.}$$

$$\text{Inductance per wire} = 0.01662 \text{ henry.}$$

Capacity in farads per mile equals C.

$$C = \frac{38.8 \times 10^{-9}}{\log_{10} \frac{2D}{d}} = \frac{38.8 \times 10^{-9}}{\log_{10} \frac{72}{.41}}$$

$$= 17.4 \times 10^{-9} \text{ farads per mile.}$$

Therefore the line capacity to neutral is:

$$207 \times 10^{-9} \text{ farads.}$$

The natural period of the circuit is given by the equation:

$$\frac{2\pi}{\sqrt{LC}}$$

$$= 2 \times 3.1416 \pi \sqrt{0.01662 \times 207 \times 10^{-9}}$$

$$= 0.00036.$$

Therefore there is no danger of resonance taking place.

The voltage at the generating station equals E_g .

$$E_g = E \cosh PS + z_0 I \sinh PS.$$

P = propagation constant.

$$P^2 = \sqrt{(r + jpL)(g + jpC)}$$

r - resistance per mile = 0.52

L - inductance per mile = 0.0014.

C - capacity per mile = 17.4×10^{-9}

$$p = 2\pi f = 157$$

$$pL = .22$$

$$pC = .273 \times 10^{-5}$$

$$S = \text{distance in miles } 11.9$$

$$P = \sqrt{(6.52 \text{ j}.22 + (0 \text{ j}.273 \times 10^{-5})^2)} \\ .00154 \text{ } 56^\circ 28'$$

$$\cosh P = \cosh x \cos y + j \sinh x \sin y$$

$$Z_o = \sqrt{\frac{r \text{ j} p L}{g \text{ j} p C}}$$

$$E_g = 17900$$

To check this value of E_g the following method has been used:

$$X_c = 10^9 / 2 \times 25 \times 207 = 30800$$

$$I_c = 30000 / 2 \times 30800 \times 1.73 = .282$$

$$RI_c = 6.18 \times .282 = 1.742$$

$$X_L I_c = 2.62 \times .282 = .738$$

$$RI = 6.18 \times 133.5 = 825$$

$$X I = 2.62 \times 133.5 = 350$$

From the diagram on page 34:

$$BA = 7451.2 + 350 = 7801.2$$

$$OB = 16373.5$$

Therefore,

$$OA = 18000$$

POWER HOUSE.

Location.

The power house designed to carry the load of the proposed electrification is to be located on the bank of Lake Michigan at a point near the city of Beach, 37 miles from Chicago. This location was found most suitable from the load conditions of the road and for operating facilities of the plant.

Power Curve.

The capacity of the power house was determined from the load curve shown on plate 7. This load curve was obtained by finding the current taken by each car on the road, from the current curve for every ten minutes. The total current expressed in K.W. with an additional 19 K.W. per car to take care of heating, lighting, and air brake equipment, was plotted against time. This resultant curve constitutes the load curve.

From this curve the peak loads were found to be 14,500 K.W. and 14,000 K.W. occurring at



8:00 A.M. and 6:00 P.M., respectively, and the average minimum load to be about 2500 K.W. at 3:00 A.M.

The generating units were chosen so that the plant would operate at about the same efficiency for all loads. In order to make the plant flexible and accomplish the mentioned result the following units were selected: three 5000 K.W. and one 3000 K.W., making a total of 18,000 K.W. rated capacity. The additional capacity was provided to serve as a reserve in case of breakdown of some unit.

Equipment.

The driving units are high pressure turbines of the Curtis horizontal type, equipped with Wheeler surface condenser of 18,000 square feet for the 5000 K.W. units and 14,000 square feet for the 3000 K.W. units.

The condensing pumps are: circulating pump, 18-inch, D.A. Volute pump, turbine driven, 24-inch suction and discharge; hot well

pump, 23 inch, 2 stage, turbine driven; vacuum pump, Wheeler tandem rotary dry vacuum pump for 18,000 and 14,000 square feet condenser, respectively.

The exciters: one 200 K.W. 110 volt General Electric, driven by Curtis non-condensing steam turbine, and one 200 K.W. 110 volt motor driven.

One 40 ton Century Crane.

The transformers, K_2 oil switches, low tension buses, and selector switches are located on the main floor at the side of the engine room. The H_6 oil switches, high tension buses, and operating board are on the second floor. The lightning arresters, choke coils, and line outlets are on the third floor.

The rheostats and storage batteries are located on the basement floor.

Boiler Room.

The boiler equipment consists of 16- 750 boiler horsepower Babcock and Wilcox water tube boilers equipped with chain grate automatic



stokers and superheater, furnishing steam at 200 lbs. gauge and 150 degrees superheat.

The water heater: 1 #8 Stilwell, horizontal 1200 H.F. heater.

Boiler feed pumps: two Alberger turbine driven boiler feed pumps of 5000 boiler horse power capacity, operating in multiple.

The coal and ash handling equipment consists of two sets of bucket conveyors running parallel to the length of the boiler room. Each set of conveyors handles both coal and ash for one row of boilers. Coal bunkers of sufficient capacity are placed above the boiler settings and have gravity feed downspouts.

Chimneys: four 9-foot diameter brick chimneys, 150 feet high.

The over-all dimensions of the plant are: length: 212 feet; width: 197 feet; height: 64 feet.

SWITCHBOARD.

The switch board is of the desk type. The operating stand is so situated that the operator has a clear view of the whole engine room. The instruments are above the operating stand.

The list of instruments is as follows:

- 7 D.C. Ammeters.
- 14 A.C. Ammeters.
- 3 D.C. Voltmeters.
- 5 A.C. Voltmeters.
- 4 Power factor indicators.
- 6 Indicating wattmeters.
- 4 Recording wattmeters.
- 1 Frequency meter.

These instruments comprise the D.C. and A.C. sides of the operating board. The D.C. instruments are used for the field excitation and exciters.

The control is all of the remote type. For the low tension side there are:

- 11 K_2 Oil switches.
- 8 H_3 Oil switches.

4 Motor controlled governors.

6 Remote controlled rheostats.

The K_2 and H_3 oil switches and the circuit breakers are all solenoid operated. The engine governors are controlled from the operating stand through a small motor.

The general arrangement of the switchboard is made up of a storage battery panel for emergency, a steam driven exciter panel, an induction motor driven exciter panel, four steam driven generator panels, and one feeder panel. The battery panel has an ammeter and voltmeter with a switch and rheostat for charging or discharging the batteries. The steam driven exciter has an ammeter and voltmeter with circuit breaker control. For the induction motor starting, a compensator is used, giving half voltage for starting. This panel has an ammeter and voltmeter. The generator panels each have three ammeters, a voltmeter, power factor indicator, indicating wattmeter, and recording wattmeter. An overload signal lamp is also used. The feeder panels have two ammeters

and two indicating wattmeters, one ammeter and one wattmeter being used on each outgoing line. This is made possible by having a balanced load at all times, since all of the power is supplied to rotary converters.

The operating stand is 14 feet long, 5 feet wide, and 8 feet high. The desk stand is 2 feet 8 inches high at the front and 3 feet 4 inches high at the rear.

The voltage generated is 6600 volts and this is stepped up to 30,820 volts through three single phase transformers connected to each generator. The capacity of the transformers for the 3000 K.W. unit is 1000 K.W. each and for the 5000 K.W. unit is 1600 K.W. each.

	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T	U	V	W	X	Y	Z	AA	AB	AC	AD	AE	AF	AG	AH	AI	AJ	AK	AL	AM	AN	AO	AP	AQ	AR	AS	AT	AU	AV	AW	AX	AY	AZ	BA	BB	BC	BD	BE	BF	BG	BH	BI	BJ	BK	BL	BM	BN	BO	BP	BQ	BR	BS	BT	BU	BV	BW	BX	BY	BZ	CA	CB	CC	CD	CE	CF	CG	CH	CI	CJ	CK	CL	CM	CN	CO	CP	CQ	CR	CS	CT	CU	CV	CW	CX	CY	CZ	DA	DB	DC	DD	DE	DF	DG	DH	DI	DJ	DK	DL	DM	DN	DO	DP	DQ	DR	DS	DT	DU	DV	DW	DX	DY	DZ	EA	EB	EC	ED	EE	EF	EG	EH	EI	EJ	EK	EL	EM	EN	EO	EP	EQ	ER	ES	ET	EU	EV	EW	EX	EY	EZ	FA	FB	FC	FD	FE	FF	FG	FH	FI	FJ	FK	FL	FM	FN	FO	FP	FQ	FR	FS	FT	FU	FV	FW	FX	FY	FZ	GA	GB	GC	GD	GE	GF	GG	GH	GI	GJ	GK	GL	GM	GN	GO	GP	GQ	GR	GS	GT	GU	GV	GW	GX	GY	GZ	HA	HB	HC	HD	HE	HF	HG	HH	HI	HJ	HK	HL	HM	HN	HO	HP	HQ	HR	HS	HT	HU	HV	HW	HX	HY	HZ	IA	IB	IC	ID	IE	IF	IG	IH	II	IJ	IK	IL	IM	IN	IO	IP	IQ	IR	IS	IT	IU	IV	IW	IX	IY	IZ	JA	JB	JC	JD	JE	JF	JG	JH	JI	IJ	JK	JL	JM	JN	JO	JP	JQ	JR	JS	JT	JU	JV	JW	JX	JY	JZ	KA	KB	KC	KD	KE	KF	KG	KH	KI	KJ	KK	KL	KM	KN	KO	KP	KQ	KR	KS	KT	KU	KV	KW	KX	KY	KZ	LA	LB	LC	LD	LE	LF	LG	LH	LI	LJ	LK	LL	LM	LN	LO	LP	LQ	LR	LS	LT	LU	LV	LW	LX	LY	LZ	MA	MB	MC	MD	ME	MF	MG	MH	MI	MJ	MK	ML	MM	MN	MO	MP	MQ	MR	MS	MT	MU	MV	MW	MX	MY	MZ	NA	NB	NC	ND	NE	NF	NG	NH	NI	NJ	NK	NL	NM	NN	NO	NP	NQ	NR	NS	NT	NU	NV	NW	NX	NY	NZ	OA	OB	OC	OD	OE	OF	OG	OH	OI	OJ	OK	OL	OM	ON	OO	OP	OQ	OR	OS	OT	OU	OV	OW	OX	OY	OZ	PA	PB	PC	PD	PE	PF	PG	PH	PI	PJ	PK	PL	PM	PN	PO	PQ	PR	PS	PT	PU	PV	PW	PX	PY	PZ	QA	QB	QC	QD	QE	QF	QG	QH	QI	QJ	QK	QL	QM	QN	QO	QP	QQ	QR	QS	QT	QU	QV	QW	QX	QY	QZ	RA	RB	RC	RD	RE	RF	RG	RH	RI	RJ	RK	RL	RM	RN	RO	RP	RQ	RR	RS	RT	RU	RV	RW	RX	RY	RZ	SA	SB	SC	SD	SE	SF	SG	SH	SI	SJ	SK	SL	SM	SN	SO	SP	SQ	SR	SS	ST	SU	SV	SW	SX	SY	SZ	TA	TB	TC	TD	TE	TF	TG	TH	TI	TJ	TK	TL	TM	TN	TO	TP	TQ	TR	TS	TU	TV	TW	TX	TY	TZ	UA	UB	UC	UD	UE	UF	UG	UH	UI	UJ	UK	UL	UM	UN	UO	UP	UQ	UR	US	UT	UU	UV	UW	UX	UY	UZ	VA	VB	VC	VD	VE	VF	VG	VH	VI	VJ	VK	VL	VM	VN	VO	VP	VQ	VR	VS	VT	VU	VV	VW	VX	VY	VZ	WA	WB	WC	WD	WE	WF	WG	WH	WI	WJ	WK	WL	WM	WN	WO	WP	WQ	WR	WS	WT	WU	WV	WW	WX	WY	WZ	XA	XB	XC	XD	XE	XF	YG	YH	YI	YJ	YK	YL	YM	YN	YO	YP	YQ	YR	YS	YT	YU	YV	YW	YX	YY	YZ	ZA	ZB	ZC	ZD	ZE	ZF	ZG	ZH	ZI	ZJ	ZK	ZL	ZM	ZN	ZO	ZP	ZQ	ZR	ZS	ZT	ZU	ZV	ZW	ZX	ZY	ZZ
Accounting Personnel	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	100																																																																																																																																																																																																																																																																																															

SOUTHEAST SCHEDULE

[illegible]

PLATE-6






PLATE 7
POWER CURVE








Signal: Pacific Wind
Date: 11/1/10

PLATE 5

[illegible]




SUB-STATION
 FOR
 PROPOSED ELECTRIFICATION
 OF
 THE MILWAUKEE BRANCH
 CHICAGO AND NORTHWESTERN RY.
 ARMOUR INSTITUTE OF TECHNOLOGY
 SCALE $\frac{1}{4}'' = 2'$




- (1) POTENTIAL PLUS METERAGE
- (2) SYNCHRONIZING (3) OVERFIELD
- (4) CENTRAL BUTTONS
- (5) RED SIGNAL LAMP
- (6) GREEN SIGNAL LAMP
- (7) CLOSURE INDICATOR FOR TRIP


POWER HOUSE SWITCH BOARD
 FOR
PROPOSED ELECTRIFICATION
 OF
THE MILWAUKEE BRANCH
CHICAGO AND NORTHWESTERN RY.
ARMOUR INSTITUTE OF TECHNOLOGY
 SCALE 1/2" = 1"




- 1. LINE PANEL
- 2. TRANSFORMER PANEL
- 3. TOTAL LOAD PANEL
- 4. METER PANEL
- 5. METER PANEL
- 6. METER PANEL
- 7. METER PANEL
- 8. METER PANEL
- 9. METER PANEL
- 10. METER PANEL
- 11. METER PANEL
- 12. METER PANEL
- 13. METER PANEL
- 14. METER PANEL
- 15. METER PANEL
- 16. METER PANEL
- 17. METER PANEL
- 18. METER PANEL
- 19. METER PANEL
- 20. METER PANEL
- 21. METER PANEL
- 22. METER PANEL
- 23. METER PANEL
- 24. METER PANEL
- 25. METER PANEL
- 26. METER PANEL
- 27. METER PANEL
- 28. METER PANEL
- 29. METER PANEL
- 30. METER PANEL
- 31. METER PANEL
- 32. METER PANEL
- 33. METER PANEL
- 34. METER PANEL
- 35. METER PANEL
- 36. METER PANEL
- 37. METER PANEL
- 38. METER PANEL
- 39. METER PANEL
- 40. METER PANEL
- 41. METER PANEL
- 42. METER PANEL
- 43. METER PANEL
- 44. METER PANEL
- 45. METER PANEL
- 46. METER PANEL
- 47. METER PANEL
- 48. METER PANEL
- 49. METER PANEL
- 50. METER PANEL
- 51. METER PANEL
- 52. METER PANEL
- 53. METER PANEL
- 54. METER PANEL
- 55. METER PANEL
- 56. METER PANEL
- 57. METER PANEL
- 58. METER PANEL
- 59. METER PANEL
- 60. METER PANEL
- 61. METER PANEL
- 62. METER PANEL
- 63. METER PANEL
- 64. METER PANEL
- 65. METER PANEL
- 66. METER PANEL
- 67. METER PANEL
- 68. METER PANEL
- 69. METER PANEL
- 70. METER PANEL
- 71. METER PANEL
- 72. METER PANEL
- 73. METER PANEL
- 74. METER PANEL
- 75. METER PANEL
- 76. METER PANEL
- 77. METER PANEL
- 78. METER PANEL
- 79. METER PANEL
- 80. METER PANEL
- 81. METER PANEL
- 82. METER PANEL
- 83. METER PANEL
- 84. METER PANEL
- 85. METER PANEL
- 86. METER PANEL
- 87. METER PANEL
- 88. METER PANEL
- 89. METER PANEL
- 90. METER PANEL
- 91. METER PANEL
- 92. METER PANEL
- 93. METER PANEL
- 94. METER PANEL
- 95. METER PANEL
- 96. METER PANEL
- 97. METER PANEL
- 98. METER PANEL
- 99. METER PANEL
- 100. METER PANEL

SUB-STATION WIRING DIAGRAM
 FOR
 PROPOSED ELECTRIFICATION
 OF
 THE MILWAUKEE BRANCH
 CHICAGO AND NORTHWESTERN RY.
 ARMOUR INSTITUTE OF TECHNOLOGY







POWER HOUSE

FIG.

PROPOSED ELECTRIFICATION


OF


THE MILWAUKEE BRANCH


CHICAGO AND NORTHWESTERN RY.


ARMOUR INSTITUTE OF TECHNOLOGY


SCALE 1/4" = 1'















POWER HOUSE
FOR
PROPOSED ELECTRIFICATION
OF
THE MILWAUKEE BRANCH
CHICAGO AND NORTHWESTERN RY.
ARMOUR INSTITUTE OF TECHNOLOGY
SCALE 1/8" = 1'








EXTERNAL WIRING OF 75 OHM ANTENNA



INTERNAL WIRING OF 400 OHM ANTENNA



INTERNAL WIRING OF 400 OHM ANTENNA



POWER HOUSE WIRING DIAGRAM
 PROPOSED ELECTRIFICATION
 OF
 THE MILWAUKEE BRANCH
 CHICAGO AND NORTHWESTERN RY.
 ARMOUR INSTITUTE OF TECHNOLOGY

CHICAGO


ALTITUDE
MILES PER HOUR
DISTANCE IN FEET


115 44
135 36
105 32
75 20
45 12
15 8

CHICAGO

CLYDEMAN

10250






DEERING

GROSS PARK

CUYLER




RAVENSWOOD

SAMMERDALE

ROSE HILL

NEW




Profile in the PAPER, PLATE A.
EUGENE DISTINGEN CO.

"Perfect" PROFILE PAPER, PLATE A.
EUGENE DISTINGEN CO.

HEMPHRE

ROGERS PARK

MAIN ST



"Perfect" PROFILE PAPER PLATE A.
EUGENE DIETZGEN


"Perfect" PROFILE PAPER
EUGENE DIETZGEN

MAIN ST.

DEMETER ST.

EVANSTON

CENTRAL ST.




KENIL WORTH

Perfect PROFILE PAPER. PLATE A.
EUGENE DIETZGEN Co.

"Perfect" PROFILE PAPER. PLATE A.
EUGENE DIETZGEN Co.

WINNETKA

HUBBARD WOODS




"Profile" PROFILE PA. PLATE A.
EUGENE H. HART

HIGHLAND PARK


HIGHWOOD

FORT SHERIDAN




FORT SHERIDAN


LAKE FOREST



"Perfect" PROFILE PAPER, PLATE A.
EUGENE DISTZGEN Co.

"Perfect" PROFILE PAPER, PLATE A.
EUGENE DISTZGEN Co.






Perfect PROFILE PAPER. PLATE A.
EUGENE DIETZGEN & CO.
EUGENE DIETZGEN & CO.
EUGENE DIETZGEN & CO.


Perfect PROFILE PAPER. PLATE A.
EUGENE DIETZGEN & CO.
EUGENE DIETZGEN & CO.
EUGENE DIETZGEN & CO.

GREAT LAKES

NORTH CHICAGO




WAUKESHA



"Superficial" PROFILE PAPER. PLATE A.
EUGENE DISTINGEN Co.

"Superficial" PROFILE PAPER. PLATE A.
EUGENE DISTINGEN Co.




"Perfect" PROFILE PAPER. PLATE A.
EUGENE DISTGENCO.


"Perfect" PROFILE PAPER.
EUGENE DISTGENCO.


CAMP LOBAN

WINTHROP HARBOR




KENDOSHA





BERRYVILLE



RACINE



"Defect" PROFILE PAPER. PLATE A.
EUGENE DIETZGEN & CO.

COUNTY LINE


"*Perfect*" PROFILE PAPER. PLATE A
EUGENE DIETZGEN Co.


"Source" FILE PA

COUNTY LINE

CARTERSVILLE







ALLIS

MILWAUKEE

AMILES

MILES PER HOUR

165

45

135

36

105

24

75

20

45

12

15

4

